



POSITION OF FIRE TAG LABEL

The position of the fire tag label shall be as follows:

- (a) For side-hung fire-resistant doorsets sufficient labelling shall be fixed to the edge of the hinge stile of the door leaf and to the door frame at approximately 1.5m above floor level;
- (b) For two-leaf fire-resistant doorsets each leaf of the door shall be labelled;
- (c) Where the installation of a label on the edge of the fire-resistant doorsets is likely to compromise the performance of the door, the label shall be relocated to the face of the door leaf at its top-hinged corner; and
- (d) Location – The location of the labels shall be as follows:
 - (i) Two-leafed door sets – Each leaf of a two-leafed doorset shall be labelled
 - (ii) Label installation – Where the installation of a label on the edge of the door is likely to compromise the performance of the door, the label shall be relocated to the face of the door leaf at its top hinged corner.
 - (iii) The label shall not be affixed over the intumescent strip

PLEASE NOTE: TAGS MUST BE MECHANICALLY FIXED, EITHER SCREW OR RIVET

