



One Piece Steel Jamb Into Concrete



1. One Piece Steel Reveal (1.6mm Thick)
2. Smoke Seal (RP120/ RP150)
3. Approved Fyre Rated Sealant
Continuous around the Jamb
- H.B Fuller Fire Sealant
Supplied by RCD
4. Fyreline Gib
5. Concrete
6. 6g (Gauge) x 150-200mm Screws



- This drawing is copyrighted and the author's property and must not be retained, copied or used without the authority of Restruct Commercial Doors Ltd.

- Do not scale from the drawing; use the provided dimensions only.

- Bring all discrepancies to the attention of the author.

- Restruct Commercial Doors do not take responsibility for the measurements provided by others.

Description:

Drawing Title:

Drawing Status:

Scale At - A3

Approved:

Job #: Revision:


Drawing by:

Checked by:



Name: Sign:

Date:


Non-Hinge Side View



Hinge Side View



- 1. One Piece Steel Reveal (1.6mm Thick)
- 2. Smoke Seal (RP120/ RP150)
- 3. Approved Fyre Rated Sealant
Continuous around the Jamb
- H.B Fuller Fire Sealant
Supplied by RCD
- 4. Fyreline Gib
- 5. Concrete
- 6. Door
- 7. Intumescent Fire Seals (RP2004) On Door



- This drawing is copyrighted and the author's property and must not be retained, copied or used without the authority of Restruct Commercial Doors Ltd.

- Do not scale from the drawing; use the provided dimensions only.


- Bring all discrepancies to the attention of the author.

- Restruct Commercial Doors do not take responsibility for the measurements provided by others.

Description:	
Drawing Title:	
Drawing Status:	
Scale At - A3	
Approved:	
Job #:	Revision:
Drawing by:	
Checked by:	
Name:	Sign:
Date:	


Top View

Up To -/60/30SM
One Piece Steel Jamb into Concrete




1. One Piece Steel Reveal (1.6mm Thick)
2. Smoke Seal (RP120/ RP150)
3. Approved Fyre Rated Sealant
Continuous around the Jamb
- H.B Fuller Fire Sealant
Supplied by RCD
4. Fyrelime Gib
5. Concrete
6. Door
7. Intumescent Fire Seals (RP2004) On Door
8. 6g (Gauge) x 150-200mm Screws

Non-Hinge Side View




Hinge Side View



Intumescent Fire Seals (RP2004)

Full Wall Make-up Top View



- This drawing is copyrighted and the author's property and must not be retained, copied or used without the authority of Restruct Commercial Doors Ltd.

- Do not scale from the drawing; use the provided dimensions only.

- Bring all discrepancies to the attention of the author.

- Restruct Commercial Doors do not take responsibility for the measurements provided by others.

Description:

Drawing Title:

Drawing Status:

Scale At - A3

Approved:

Job #: Revision:

Drawing by:

Checked by:

Name: Sign:

Date: